




# TRANSFER LIMIT ADVICE - TASMANIA AND SA FCAS

FOR THE NATIONAL ELECTRICITY MARKET

PUBLISHED JULY 2014 





## IMPORTANT NOTICE

### Purpose

AEMO has prepared this document to provide information about how AEMO calculates contingency frequency control ancillary services requirements in Tasmania and South Australia, as at the date of publication.

### Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law (NEL), the National Electricity Rules (NER), or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

Copyright 2014. Australian Energy Market Operator Limited. The material in this publication may be used in accordance with the copyright permissions on AEMO's website



## VERSION RELEASE HISTORY

| Version number | Release date     | Author    | Comments   |
|----------------|------------------|-----------|--|
| 2              | 1 July 2014      | Ben Blake | Added factors for modelling the fast response of Basslink's frequency controller, updated to new AEMO template |
| 1              | 21 November 2013 | Ben Blake | Initial version  |



# CONTENTS

|  |           |
|--|-----------|
| <b>IMPORTANT NOTICE</b>                              | <b>2</b>  |
| <b>VERSION RELEASE HISTORY</b>                       | <b>3</b>  |
| <b>1. INTRODUCTION</b>                               | <b>6</b>  |
| 1.1. Methodology                                     | 6         |
| 1.2. Conversion to Constraint Equations              | 6         |
| <b>2. TASMANIA</b>                                   | <b>7</b>  |
| 2.1. Basslink trip for Tasmania to Victoria Transfer | 7         |
| 2.2. Tasmanian Generator Trip                        | 11        |
| 2.3. Tasmanian Load Trip                             | 13        |
| <b>3. SOUTH AUSTRALIA</b>                            | <b>17</b> |
| 3.1. South Australia Island Generator Trip           | 17        |
| 3.2. South Australia Island Load Trip                | 19        |
| <b>MEASURES AND ABBREVIATIONS</b>                    | <b>22</b> |
| 3.3. Units of measure                                | 22        |
| 3.4. Abbreviations                                   | 22        |
| <b>GLOSSARY</b>                                      | <b>23</b> |

## TABLES

|   |    |
|---|----|
| Table 2-1 – Tasmania Raise 6 second coefficients for trip of Basslink                                       | 8  |
| Table 2-2 – Tasmania Raise 60 second coefficients for trip of Basslink                                      | 8  |
| Table 2-3 – Tasmania Raise 5 minute coefficients for trip of Basslink                                       | 8  |
| Table 2-4 – Tasmania Raise 6 second coefficients for trip of Basslink (650 ms)                              | 9  |
| Table 2-5 – Tasmania Raise 60 second coefficients for trip of Basslink (650 ms)                             | 10 |
| Table 2-6 – Tasmania Raise 5 minute coefficients for trip of Basslink (650 ms)                              | 11 |
| Table 2-7 – Raise coefficients for a Tasmanian generator trip – Basslink able to transfer FCAS              | 11 |
| Table 2-8 – Raise 6 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS   | 12 |
| Table 2-9 – Raise 60 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS  | 13 |
| Table 2-10 – Raise 5 minute coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS  | 13 |
| Table 2-11 – Lower coefficients for a Tasmanian generator trip – Basslink able to transfer FCAS             | 14 |
| Table 2-12 – Lower 6 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS  | 14 |
| Table 2-13 – Lower 60 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS | 15 |
| Table 2-14 – Lower 5 minute coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS  | 16 |
| Table 3-1 – South Australia Raise 6 second coefficients for a generator trip                                | 17 |
| Table 3-2 – South Australia Raise 60 second coefficients for a generator trip                               | 18 |
| Table 3-3 – South Australia Raise 5 minute coefficients for a generator trip                                | 19 |
| Table 3-1 – South Australia Lower 6 second coefficients for a load trip                                     | 19 |



|  |    |
|--|----|
| Table 3-1 – South Australia Lower 60 second coefficients for a load trip | 20 |
| Table 3-1 – South Australia Lower 5 minute coefficients for a load trip  | 21 |

## FIGURES

|  |    |
|--|----|
| Figure 2-1 – Threshold equation for non-linear requirement   | 7  |
| Figure 2-2 – Raise 6 second requirement for Tasmanian demand of 1600 MW and inertia = 5000 MWs         | 9  |
| Figure 2-3 – Raise 60 second requirement for Tasmanian demand of 1600 MW and inertia = 5000 MWs        | 10 |
| Figure 2-4 – Raise 5 minute requirement for Tasmanian demand of 1600 MW and inertia = 5000 MWs         | 10 |
| Figure 2-5 – Raise 6 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs         | 12 |
| Figure 2-6 – Raise 60 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs        | 12 |
| Figure 2-7 – Raise 5 minute requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs         | 13 |
| Figure 2-8 – Lower 6 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs         | 14 |
| Figure 2-9 – Lower 60 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs        | 15 |
| Figure 2-10 – Lower 5 minute requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs        | 16 |
| Figure 3-1 – Raise 6 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs  | 17 |
| Figure 3-2 – Raise 60 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs | 18 |
| Figure 3-3 – Raise 5 minute requirement for South Australian demand of 1600 MW and inertia = 6500 MWs  | 18 |
| Figure 3-4 – Lower 6 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs  | 19 |
| Figure 3-5 – Lower 60 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs | 20 |
| Figure 3-6 – Lower 5 minute requirement for South Australian demand of 1600 MW and inertia = 6500 MWs  | 20 |



# 1. INTRODUCTION

The Tasmanian and SA (island and at risk of islanding) FCAS requirements are calculated taking into account both the demand and the inertia. The determination of these requirements is complex and requires an iterative calculation process so for Dispatch the contingency FCAS requirements in Tasmania (excluding those for a trip of Basslink or trip of Murraylink) are calculated by an application in AEMO's energy management system (EMS), called XDFCAS. Pre-dispatch uses an approximation of the calculation done by XDFCAS as XDFCAS only operates in real-time.

For the Basslink trip case, the FCAS requirements also need to include the effect of the frequency control system protection scheme (FCSPS). The impact of the FCSPS creates an FCAS requirement that is highly non-linear over the full range of Basslink flows. Relying on XDFCAS could result in significant over-enablement of FCAS should Basslink flow be dispatched from a low level to a high level of transfer. To avoid this, FCAS requirements are calculated using constraint equations that reflect the non-linear characteristic.

The methodology described below details how the pre-dispatch and Basslink trip constraint equations are formulated.

## 1.1. Methodology

Due to the complexity of modelling the contingency FCAS requirements calculated by XDFCAS, regression analysis was used to calculate factors on the main inputs to XDFCAS. Using a spread sheet version of XDFCAS the contingency FCAS requirements were calculated for hundreds of cases representing differing demands, inertia, generation or load at risk or interconnector flows. Multiple variable regression analysis was used to calculate the factors on these inputs.

## 1.2. Conversion to Constraint Equations

This document does not describe how AEMO implements these limit equations as constraint equations in the NEM market systems. This is covered in the Constraint Formulation Guidelines and Constraint Implementation Guidelines.

## 2. TASMANIA

### 2.1. Basslink trip for Tasmania to Victoria Transfer

For the trip of Basslink two scenarios are considered. The normal case has Basslink tripping after 400 ms and when at risk of tripping due to lightning the tripping time is set at 650 ms. Changing this value has a significant impact on the regression.


The analysis indicated that the overall FCAS requirements for the 6 and 60 sec services are highly non-linear. For better modelling the regression was separated into 4 segments for 650ms trip time and 2 segments for 400ms trip time. Except for first segment of the Basslink trip case, the data used for each segment was chosen from the range of FCAS requirements which maximised the correlation with the XDFCAS results.

The 5 min services had very little non-linearity so only a single segment was required in both cases.

#### 2.1.1. Effect of the FCSPS

It was observed that when there was sufficient inertia available in Tasmania, the action of the FCSPS for a trip of Basslink gave a linear FCAS requirement. Additionally, the amount of inertia required was dependent on the Tasmanian demand. This was used as the basis for a method of switching between the linear segment and the 3 non-linear segments. The ratio of Tasmanian Inertia / Tasmanian Demand coinciding with the point where the FCAS requirement started becoming non-linear was graphed. From this graph a ratio threshold equation was determined.

**Figure 2-1 – Threshold equation for non-linear requirement**



From Figure 2-1 the ratio threshold equation is:

$$\begin{aligned}
 \text{Ratio Threshold} &= 0.00000209 * \text{Tasmanian Demand}^2 \\
 &- 0.00769 * \text{Tasmanian Demand} \\
 &+ 11.253
 \end{aligned}$$



### 2.1.2. System Normal

The following cases consider Basslink tripping in 400 ms.

**Table 2-1 – Tasmania Raise 6 second coefficients for trip of Basslink**

| Term                  | Segment 1 | Segment 2 |
|-----------------------|-----------|-----------|
| Intercept             | -11.728   | -30.807   |
| Tasmanian Inertia     | -0.0012   | -0.0432   |
| Basslink (Tas to Vic) | -0.0399   | -0.267    |
| Tasmanian Demand      | 0.0541    | 0.15      |

**Table 2-2 – Tasmania Raise 60 second coefficients for trip of Basslink**

| Term                  | Segment 1 | Segment 2 |
|-----------------------|-----------|-----------|
| Intercept             | -15.504   | -25.7     |
| Tasmanian Inertia     | -0.00112  | -0.0436   |
| Basslink (Tas to Vic) | -0.046    | -0.266    |
| Tasmanian Demand      | 0.0665    | 0.175     |

**Table 2-3 – Tasmania Raise 5 minute coefficients for trip of Basslink**

| Term                  | Segment 1 |
|-----------------------|-----------|
| Intercept             | -13.898   |
| Tasmanian Inertia     | 0.00046   |
| Basslink (Tas to Vic) | -0.0013   |
| Tasmanian Demand      | 0.0928    |

### 2.1.3. Basslink tripping time of 650 ms

The following section details the case when Basslink is at risk of tripping due to lightning and the Basslink tripping time is 650 ms. The range of data used for the Raise 6 second regression was for XDFCAS requirements less than 150 MW (2nd equation, 150 MW to 225 MW (3rd equation) and > 225 MW for the 4th equation.



Figure 2-2 – Raise 6 second requirement for Tasmanian demand of 1600 MW and inertia = 5000 MWs




Table 2-4 – Tasmania Raise 6 second coefficients for trip of Basslink (650 ms)

| Term                  | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
|-----------------------|-----------|-----------|-----------|-----------|
| Intercept             | -11.947   | 2.908     | 33.893    | 100.355   |
| Tasmanian Inertia     | -0.00102  | -0.0142   | -0.0775   | -0.252    |
| Basslink (Tas to Vic) | -0.0408   | -0.152    | -0.7      | -2.08     |
| Tasmanian Demand      | 0.0532    | 0.0787    | 0.122     | 0.157     |
| Ratio Threshold Swamp |           | Yes       | Yes       | Yes       |

The range of data used for the Raise 60 second regression was for XDFCAS requirements less than 150 MW (2nd equation, 150 MW to 275 MW (3rd equation) and > 275 MW for the 4th equation.

Figure 2-3 – Raise 60 second requirement for Tasmanian demand of 1600 MW and inertia = 5000 MWs





Table 2-5 – Tasmania Raise 60 second coefficients for trip of Basslink (650 ms)

| Term                  | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
|-----------------------|-----------|-----------|-----------|-----------|
| Intercept             | -14.934   | 1.046     | 32.21     | 197.824   |
| Tasmanian Inertia     | -0.00128  | -0.0129   | -0.0772   | -0.285    |
| Basslink (Tas to Vic) | -0.051    | -0.154    | -0.7      | -2.27     |
| Tasmanian Demand      | 0.0665    | 0.088     | 0.151     | 0.165     |
| Ratio Threshold Swamp |           | Yes       | Yes       | Yes       |

Figure 2-4 – Raise 5 minute requirement for Tasmanian demand of 1600 MW and inertia = 5000 MWs



**Table 2-6 – Tasmania Raise 5 minute coefficients for trip of Basslink (650 ms)**

| Term                  | Segment 1 |
|-----------------------|-----------|
| Intercept             | -13.898   |
| Tasmanian Inertia     | 0.00046   |
| Basslink (Tas to Vic) | -0.0013   |
| Tasmanian Demand      | 0.0928    |

## 2.2. Tasmanian Generator Trip

The following factors were generated (for the trip of a single large generator or multiple generators) using the same methodology as outlined in section 1.1. The inertia used in each case is the total inertia in Tasmania less the inertia being supplied by the contingent units.

Note: Due to the highly non-linear nature of the FCAS requirements in Tasmania, the maximum generation at risk is to be capped at 250 MW. This is pending further studies to determine the veracity of the XDFCAS calculations and other possible effects on the power system.

### 2.2.1. Basslink able to transfer FCAS

The following factors are to be used in the case when Basslink is able to transfer FCAS. These take into account the fast response of Basslink's frequency controller<sup>1</sup>. The frequency level used for the 60 second service is 0.01 Hz different to the 6 second service.

**Table 2-7 – Raise coefficients for a Tasmanian generator trip – Basslink able to transfer FCAS**

| Term                            | R6 Factors | R60 Factors | R5 Factors |
|---------------------------------|------------|-------------|------------|
| Intercept                       | 30.2822    | -18.0862    | 0.6678     |
| Basslink headroom               | -1.4479    | -0.6915     | -1.0122    |
| Musselroe MW                    | 0.0341     | -0.0242     | 0.0008     |
| Bluff Point MW                  | 0.0154     | -0.0115     | 0.0004     |
| Studland Bay MW                 | 0.0283     | -0.0200     | 0.0007     |
| Tas MW at risk                  | 1.3759     | 0.7967      | 1.0083     |
| Tasmanian Demand                | -0.0490    | -0.0262     | -0.0037    |
| Tasmanian Inertia - Contingency | -0.008811  | 0.002653    | 0.000250   |

### 2.2.2. Basslink unable to transfer FCAS

In dispatch when Basslink is unable to transfer FCAS the requirements for Tasmanian generator trip(s) use the real-time FCAS requirements calculator – XDFCAS. The following factors are used in Pre-dispatch. The maximum of the 4 equations is to be implemented as the pre-dispatch RHS.

<sup>1</sup> AEMO, *FCAS calculation changes in Tasmania*, Available at: <http://www.aemo.com.au/Electricity/Market-Operations/Congestion-Information-Resource/FCAS-calculations-changes-in-Tasmania>. Viewed on 30 June 2014.

Figure 2-5 – Raise 6 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs





Table 2-8 – Raise 6 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS

| Term                            | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
|---------------------------------|-----------|-----------|-----------|-----------|
| Intercept                       | 8.15916   | 50.28354  | 40.9621   | 54.19972  |
| Tasmanian Inertia - Contingency | -0.0024   | -0.02375  | -0.04297  | -0.06793  |
| Tas MW at risk                  | 0.99135   | 1.78517   | 2.5304    | 3.20369   |
| Tasmanian Demand                | -0.03288  | -0.05393  | -0.07596  | -0.09399  |


Figure 2-6 – Raise 60 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs



**Table 2-9 – Raise 60 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS**

| Term                            | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
|---------------------------------|-----------|-----------|-----------|-----------|
| Intercept                       | 7.49543   | 57.31124  | 58.99631  | 60.59392  |
| Tasmanian Inertia - Contingency | -0.00249  | -0.02452  | -0.04429  | -0.08397  |
| Tas MW at risk                  | 1.21537   | 2.01016   | 2.80255   | 4.00339   |
| Tasmanian Demand                | -0.04043  | -0.05786  | -0.08347  | -0.1139   |

**Figure 2-7 – Raise 5 minute requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs**



**Table 2-10 – Raise 5 minute coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS**

| Term                            | Segment 1 |
|---------------------------------|-----------|
| Intercept                       | -11.2192  |
| Tasmanian Inertia - Contingency | 0.00138   |
| Tas MW at risk                  | 0.88728   |
| Tasmanian Demand                | 0.01041   |

## 2.3. Tasmanian Load Trip

The following factors were generated (for the trip of a single large load and multiple loads) using the same methodology as outlined in 1.1.

### 2.3.1. Basslink able to transfer FCAS

The following factors are to be used in the case when Basslink is able to transfer FCAS. These take into account the fast response of Basslink’s frequency controller. The frequency level used for the 60 second service is 0.01 Hz different to the 6 second service.


**Table 2-11 – Lower coefficients for a Tasmanian generator trip – Basslink able to transfer FCAS**

| Term              | L6 Factors | L60 Factors | L5 Factors |
|-------------------|------------|-------------|------------|
| Intercept         | 11.3686    | -2.1591     | -0.2984    |
| Basslink headroom | -1.4431    | -0.9198     | -1.0059    |
| Tas MW at risk    | 1.3594     | 0.9351      | 1.0074     |
| Tas Demand        | -0.0467    | -0.0371     | -0.0031    |
| Tas Inertia       | -0.005272  | 0.000636    | 0.000235   |

**2.3.2. Basslink unable to transfer FCAS**

In dispatch when Basslink is unable to transfer FCAS the requirements for Tasmanian load trip(s) is to use the XDFCAS. The following factors are used in pre-dispatch. The maximum of the 4 equations is to be implemented as the pre-dispatch RHS.

**Figure 2-8 – Lower 6 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs**



**Table 2-12 – Lower 6 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS**

| Term                            | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
|---------------------------------|-----------|-----------|-----------|-----------|
| Intercept                       | 9.76      | 42.063    | 13.41     | -98.697   |
| Tasmanian Inertia - Contingency | -0.001396 | -0.029565 | -0.085366 | -0.206736 |
| Tas MW at risk                  | 0.86338   | 2.09199   | 3.75816   | 6.1941    |
| Tasmanian Demand                | -0.02747  | -0.06402  | -0.11222  | -0.18064  |

Figure 2-9 – Lower 60 second requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs




Table 2-13 – Lower 60 second coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS

| Term                            | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
|---------------------------------|-----------|-----------|-----------|-----------|
| Intercept                       | 20.732    | 41.723    | -30.491   | -113.599  |
| Tasmanian Inertia - Contingency | -0.003455 | -0.029565 | -0.117806 | -0.296289 |
| Tas MW at risk                  | 1.18623   | 2.96564   | 5.12839   | 8.19264   |
| Tasmanian Demand                | -0.03746  | -0.08766  | -0.1514   | -0.23869  |



Figure 2-10 – Lower 5 minute requirement for Tasmanian demand of 1600 MW and inertia = 6500 MWs




Table 2-14 – Lower 5 minute coefficients for a Tasmanian generator trip – Basslink unable to transfer FCAS


| Term                            | Segment 1 |
|---------------------------------|-----------|
| Intercept                       | -7.68     |
| Tasmanian Inertia - Contingency | 0.0010471 |
| Tas MW at risk                  | 0.94558   |
| Tasmanian Demand                | 0.00271   |

### 3. SOUTH AUSTRALIA

#### 3.1. South Australia Island Generator Trip

The following limit equations are to be used when South Australia is an island for loss of the largest generating unit or for the network event connecting a group of generators (such as Lake Bonney 1, 2 and 3). They can also be used for loss of Murraylink for Vic to SA transfers.

**Figure 3-1 – Raise 6 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs**



**Table 3-1 – South Australia Raise 6 second coefficients for a generator trip**

| Term          | Segment 1 | Segment 2 |
|---------------|-----------|-----------|
| Intercept     | 43.054    | -174.5728 |
| SA Demand     | -0.0373   | -0.1447   |
| SA Inertia    | -0.005355 | -0.067216 |
| SA MW at Risk | 1.3928    | 6.1619    |

Figure 3-2 – Raise 60 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs





Table 3-2 – South Australia Raise 60 second coefficients for a generator trip

| Term          | Segment 1 |
|---------------|-----------|
| Intercept     | -11.2844  |
| SA Demand     | -0.0211   |
| SA Inertia    | 0.001679  |
| SA MW at Risk | 0.7883    |

Figure 3-3 – Raise 5 minute requirement for South Australian demand of 1600 MW and inertia = 6500 MWs




**Table 3-3 – South Australia Raise 5 minute coefficients for a generator trip**

| Term          | Segment 1 |
|---------------|-----------|
| Intercept     | 0.143     |
| SA Demand     | -0.005    |
| SA Inertia    | 0.00013   |
| SA MW at Risk | 1.0084    |

### 3.2. South Australia Island Load Trip

The following limit equations are to be used when South Australia is an island for loss of the largest load (Olympic Dam) or for the loss of Murraylink for SA to Vic to transfers.

**Figure 3-4 – Lower 6 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs**



**Table 3-4 – South Australia Lower 6 second coefficients for a load trip**

| Term          | Segment 1 | Segment 2 |
|---------------|-----------|-----------|
| Intercept     | 23.7972   | -96.0062  |
| SA Demand     | -0.0337   | -0.1298   |
| SA Inertia    | -0.00284  | -0.05566  |
| SA MW at Risk | 1.2089    | 5.3842    |

Figure 3-5 – Lower 60 second requirement for South Australian demand of 1600 MW and inertia = 6500 MWs





Table 3-5 – South Australia Lower 60 second coefficients for a load trip

| Term          | Segment 1 |
|---------------|-----------|
| Intercept     | 3.9107    |
| SA Demand     | -0.0199   |
| SA Inertia    | 0.000622  |
| SA MW at Risk | 0.7687    |

Figure 3-6 – Lower 5 minute requirement for South Australian demand of 1600 MW and inertia = 6500 MWs





**Table 3-6 – South Australia Lower 5 minute coefficients for a load trip**

| <b>Term</b>   | <b>Segment 1</b> |
|---------------|------------------|
| Intercept     | -0.0229          |
| SA Demand     | -0.0046          |
| SA Inertia    | 0.000102         |
| SA MW at Risk | 1.0063           |

## MEASURES AND ABBREVIATIONS

### 3.3. Units of measure

| Unit of measure | Expanded name   |
|-----------------|---|
| MW              | A watt (W) is a measure of power and is defined as one joule per second and it measures the rate of energy conversion or transfer. A Megawatt is one million watts. |

### 3.4. Abbreviations

Note: the inertia values in this document are in MWs unlike the inertia values from AEMO's EMS which are expressed in 100 MVA base.

| Abbreviation                    | Expanded name  |
|---------------------------------|--|
| Basslink (Tas to Vic)           | MW Transfer from Tasmania to Victoria via Basslink (measured on the Tasmanian side)  |
| Basslink headroom               | 80 % of the available headroom on Basslink capped at 100. The headroom is calculated as:<br>$80\% \times (\text{If Basslink current flow} > 50 \text{ MW then}$ $\text{Basslink Bid availability} - \text{Basslink current flow}$ $\text{Else if Basslink current flow} < -50 \text{ MW then}$ $\text{Abs (Basslink current flow)} - 50$ $\text{Else } 0)$ |
| Bluff Point MW                  | MW output of the Bluff Point wind farm   |
| Musselroe MW                    | MW output of the Musselroe wind farm   |
| SA Demand                       | Summation of the scheduled, semi-scheduled and non-scheduled generators in South Australia   |
| SA Inertia                      | Inertia of the South Australian generators in MWs  |
| SA MW at Risk                   | Generator(s), Load(s) at risk in South Australia. Murraylink is also considered a generator (for Vic to SA flows) and a load (for SA to Vic flows).  |
| Studland Bay MW                 | MW output of the Studland Bay wind farm  |
| Tas MW at Risk                  | Generator(s) or Load(s) at risk in Tasmania  |
| Tasmanian Demand                | Summation of the scheduled, semi-scheduled and non-scheduled generators in Tasmania  |
| Tasmanian Inertia               | Inertia of the Tasmanian generators in MWs   |
| Tasmanian Inertia - Contingency | The inertia of the Tasmanian generators (scheduled and non-scheduled) in MWs minus the inertia of the contingent generator(s)  |





## GLOSSARY

| Term                       | Definition  |
|----------------------------|---|
| <b>Constraint equation</b> | These are the mathematical representations that AEMO uses to model power system limitations and FCAS requirements in NEMDE.   |
| <b>Constraint function</b> | A group of RHS terms that can be referenced by one or more constraint equation RHSs. These are used where a common calculation is required multiple times (such as a complex stability limit or a calculation for a sub-regional demand). These have been referred to as generic equations, base equations or shared expressions in the past. |
| <b>Constraint set</b>      | A grouping of constraint equations that apply under the same set of power system conditions, either for system normal or plant outage(s). AEMO uses constraint sets to efficiently activate / deactivate constraint equations.  |
| <b>Mainland</b>            | The NEM regions: Queensland, New South Wales, Victoria and South Australia  |
| <b>System Normal</b>       | The configuration of the power system where: <ul style="list-style-type: none"><li>• All transmission elements are in service, or</li><li>• The network is operating in its normal network configuration</li></ul>  |